

AWTA PRODUCT TESTING

Australian Wool Testing Authority Ltd - trading as AWTA Product Testing

A.B.N 43 006 014 106

1st Floor, 191 Racecourse Road, Flemington, Victoria 3031

P.O Box 240, North Melbourne, Victoria 3051

Phone (03) 9371 2400 Fax (03) 9371 2499

TEST REPORT

Client : Aventino Group Pty Ltd T/AS Wonderwood Floors
Unit 1/27 Leeds Street
Rhodes NSW 2138

Test Number : 19-001313
Issue Date : 4/04/2019
Print Date : 16/04/2019

Sample Description Clients Ref : "Colorado Engineered Oak"
Engineered timber flooring
Colour : Oak
End Use : Flooring
Nominal Composition : Timber
Nominal Mass per Unit Area/Density : 0.53g/m³
Nominal Thickness : 15mm

AS 4586-2013 Appendix A

Slip Resistance Classification of new Pedestrian Surface Materials Wet Pendulum Test Method

Date of Testing 03/04/2019
Test Temperature (20±5degC) 22 °C
Sample Preparation Washed with pH neutral detergent and dried.
Test Direction Length
Fixed/Unfixed Unfixed
Slider No 96 Batch No 72
Length 1 2 3 4 5 SRV
British Pendulum 44 45 44 44 44 44
Number
Classification P3

Equipment: Cooper Pendulum Skid Tester Serial No: 1433-01 Calibrated 16/10/2017
Slider prepared using P400 and 3µm lapping film.

These results apply only to the specimens tested and it is recommended that before selection of flooring or paving materials the effect of service conditions, including maintenance and wear on their slip resistance be checked.

163079

34701

Page 1 of 1

© Australian Wool testing Authority Ltd
Copyright - All Rights Reserved



Accredited for compliance with ISO/IEC 17025 - Testing

- Chemical Testing

- Mechanical Testing

- Performance & Approvals Testing

: Accreditation No. 983

: Accreditation No. 985

: Accreditation No. 1356

Samples and their identifying descriptions have been provided by the client unless otherwise stated. AWTA Ltd makes no warranty, implied or otherwise, as to the source of the tested samples. The above test results relate only to the sample or samples tested. This document shall not be reproduced except in full and shall be rendered void if amended or altered. This document, the names AWTA Product Testing and AWTA Ltd may be used in advertising providing the content and format of the advertisement have been approved by the Managing Director of AWTA Ltd.



0204/11/06

APPROVED SIGNATORY

MICHAEL A. JACKSON B.Sc. (Hons)
MANAGING DIRECTOR