



**GRIPTEK ANTI-SLIP SOLUTIONS PTY LTD**  
 26a Production Avenue  
 Kogarah NSW 2217  
 AUSTRALIA  
 ABN: 13 622 802 797  
**T. 1300 01 GRIP**  
**E. info@griptek.com.au**

**Test Report No:** 291024B

**Slip Resistance Measurement of New Pedestrian Surfaces: AS4586:2013 Appendix A**

**Client:** WONDERWOOD FLOORS - U1, 27 Leeds Sreet, Rhodes NSW 2138

**Test Date:** 29/10/2024      **Temperature:** 23 Deg C.

**Test Conducted to:** AS 4586:2013 Appendix A      **Conducted by:** Sean C Murphy  
 B.A (Syd. U), Dip. Ed

**Test Method:** Wet Pendulum Testing      **Test Device:** Munro - Serial No. 2015  
 Calibration Exp. July 2025

**Surface:** Herringbone 15mm Engineered Floorboard      **Rubber Slider Used:** Slider 96 (4 S Rubber)  
 Cert. No. 158/24, Batch #31

**Slider Preparation:** Abrasive paper, Grade P400 followed by pink lapping paper wet

**Test Location:** Unit 1, 27 Leeds Street, Rhodes NSW 2138

**Surface Preparation:** Cleaned with Water & Hand Scrubbing

**Surface Application:** N/A

Tested Area:

Specimen Number	Location	Condition	Gradient %	Direction of Test	Mean BPN Last 3 swings
1	Loose Sample	As Found	<2.0	N/A	35
2	Loose Sample	As Found	<2.0	N/A	36
3	Loose Sample	As Found	<2.0	N/A	36
4	Loose Sample	As Found	<2.0	N/A	37
5	Loose Sample	As Found	<2.0	N/A	36

**Mean BPN Slip Resistance Value - SRV** 36

**Classification** P3

Interpretation of the Wet Pendulum Results	
Classification of pedestrian surface materials according to the AS 4586	Mean BPN
P5	>54
P4	45-54
P3	35-44
P2	25-34
P1	12-24
P0	<12

The AS 4586 standard provides a guide & recommendation for use, we recommend that this report be read in conjunction with AS 4586 & Handbook HB198: 2014. Refer to Table 3B of HB 198 for requirements of sloped surfaces & ramps. The results in this test do not account for any future wear, contamination or maintenance of this surface. Griptek Anti-Slip Solutions Pty Ltd or our agents, licencees or employees accept no responsibility for any actions whatsoever which may arise as a result of this test report, all information within this report is copyright & is protected by copyright law.

Approved Signatory: Michael Holt